

REQUEST FOR INFORMATION (RFI) - 1

DATE: August 21, 2006
TO: All Prospective Bidders and Plan Holders
PROJECT: “30th Avenue Soccer Park”
BID NO. B06-108E
PROJECT NO. 7007

The following is in response to an RFI:

Request: Reference plan sheet E-2. Key note #5 indicates junction boxes for future receptacles. Are these in-ground junction boxes or above grade junction boxes? What size? If these are above grade junction boxes, how are they supported?

Response: Junction boxes to accommodate above ground receptacles mounted on poles (FUTURE). Single gang junction box for typical duplex receptacle.

APPROVED:

William O. Bayne, P. E.
City Engineer